

UIC



*In Partnership
with the US DOE*

CHP Case Studies / Business Case

**Methane Recovery from Hog Waste
Integrated with Combined Heat and
Power Technologies**

November 2004

Steffen Mueller

From Biogas to Btu


- **1000 Finish, or**
- **5000 Sow Farrow to Wean**
 - Both types of farms produce around 45,000 cubic feet of biogas per day
 - With a Methane content of between 55% and 80%
 - Farm produces between 25 and 36 MMBtu per day or between 9,000 and 13,000 MMBtu per year

From Btu to kW

- **Assume a Heat Rate of 14,000 Btu/kWh (24% efficient prime mover) such as a microturbine or recip. engine**
- **25 MMBtu/day to 36 MMBtu/day can fuel prime movers of between 74 and 107 kW installed capacity**
- **A 74 to 107 kW generator produces:**
 - **between 1,700 and 2,500 kWh per day**
 - **between 53,000 and 77,000 kWh per month**
 - **Between 650,000 and 940,000 kWh per year**

Electricity Savings

Annual Electricity Savings at Various Rates



◆ 74 kW Generator ■ 107 kW Generator

Heat Recovery

Installed Capacity	Approximate Heat Recovery per Year	Required Fuel Equivalent (at 80% Boiler Efficiency) per Year	Savings from Heat Recovery @ \$5/MMBtu Gas Cost per Year	Savings from Heat Recovery @ \$7/MMBtu Gas Cost per Year
74 kW	2,700 MMBtu	3,400 MMBtu	\$17,000	\$23,700
107 kW	3,900 MMBtu	4,900 MMBtu	\$24,500	\$34,300



Total Savings Potential

- **Approximate Savings Assuming**
- **Low Case:**
5 cent/kWh avoided electricity charges and \$5/MMBtu natural gas prices
- **High Case:**
9 cents/kWh avoided electricity charges and \$7/MMBtu natural gas prices

Installed Capacity	Low Savings Case \$/Year	High Savings Case \$/Year
74 kW	49,400	82,000
107 kW	71,400	118,700

Installed Cost - Rules of Thumb

Reciprocating Engines <500kW

- Recoverable Useful Heat: 4,000 to 5,000 Btu/h per kW
- O&M Costs: \$0.012 to \$0.015 per kWh
- Installed Costs: \$1,400 to \$1,800 per kW
(with heat recovery)

Microturbines 30 to 400 kW

- Recoverable Useful Heat: 6,000 – 7,000 Btu/h per kW
- O&M Cost (*per kWh*) \$0.01 to \$0.015
- Installed Cost: \$1,000 to \$2,000
(with heat recovery)

System Paybacks – On Incremental CHP Facility Only

Capacity	Installed Cost	Yearly O&M Cost	Low Savings Case Years	High Savings Case Years
74 kW	\$120,000	\$8,500	2.9	1.6
107 kW	\$160,000	\$12,000	2.7	1.5

Case Study 1: Colorado Pork LLC

- 6,300 Sow Farrow to Wean
- Biogas Produced: 61,000 cf/day
- Anaerobic Digester with Biogas Recovery; Caterpillar 3306 engine
- Generating Capacity: 85 kW (operates at 60 kW)
- Thermal Heat Recovered: 2,200 MMBtu/Year (est.) hot water
- Heated Anaerobic Digester with CHP system installed in response to Amendment 14 regulations



Project Financials

Costs

Anaerobic Digester/Secondary Basin:	\$149,000
Pumps, Valves, Meters:	\$ 62,000
Engineering	<u>\$31,000</u>
Total Heated Anaerobic Digester:	\$242,000
85 kW Engine plus Generator:	\$115,000
CHP Plant Engineering:	<u>\$31,000</u>
Total Generating Facility Installed:	\$146,000
Total Digester + Generating Facility:	\$388,000
Alternative: Aerobic Digester:	\$100,000



Project Financials (cont'd)

Savings

From Lagoon Cleanout:	\$10,000
From Electricity:	<u>\$39,000</u>
Total Savings:	\$49,000

Payback

Heated Anaerobic Digester Only:	14.2 Years
Heated Anaerobic Digester+ Generating Facility:	7.9 Years
Incremental Generating Facility Only:	3.7 Years

Project Outcome

- **The project shows a relatively attractive payback on capital investment**
- **Anaerobic digester with CHP facility assured compliance with Amendment 14 Regulations**

Case Study 2: Afxantiou Farm in Cyprus

- **1,700 Sow Farrow to Finish Operation**
- **Anaerobic digester with biogas recovery and Caterpillar Model MCG310 engine with heat recovery**
- **Generating Capacity: 205 kW**
- **Biogas Produced: 85,000 cf/day**
- **Recoverable Heat: 7,665 MMBtu/Year**
- **Used Heat: 2,935 MMBtu/Year to meet digester heating requirements**

Project Financials

Digester & Generating Equipment Cost:

Total Cost:	\$1,380,000
Government Grant:	<u>\$ 500,000</u>
Net Cost:	\$ 880,000

Annual Savings:

Avoided Electricity:	\$210,000
Avoided Gas:	<u>\$ 18,000</u>
Total Savings:	\$228,000

Estimated Simple Payback on Total Project:

Without Grant:	6.1 Years
With Grant:	3.9 Years



Project Outcome

- The incumbent utility company's electricity rates are relatively high at 15 ¢/kWh, which makes it more attractive to self-generate the farm's electricity needs. Excess electricity can be sold back to the utility company at 8.3 ¢/kWh
- Afxantiou Farm took advantage of available grant money. The government of Cyprus is providing a \$500,000 grant for the project
- Under Cyprus' recently imposed strict environmental regulations the Farm needed to install at least a lined basin for the animal waste, an unrecoverable capital expense. By opting for an anaerobic digester with a CHP system the Farm was able to able to:
 - comply with the regulations
 - while generating revenues



Case Study 3: Barham Farms

- **4,000 sow farrow-to-wean facility**
- **Biogas Produced: 19,200 cf/day**
- **Energy Plant Equipment: Inground unheated anaerobic digester**
- **Caterpillar Model 3406NA engine**
- **Generating Capacity: 120 kW (often operated at 90 kW)**
- **Thermal Heat Recovered: 3,150 MMBtu/Year**

Project Outcome and Financials

- **The 120kW engine / generator was significantly oversized for available biogas from the digester. As a result:**
 - **The standby tariff imposed on the CHP system was based on the rated capacity of 120kW, while the CHP unit was never operated at more than 60%**
 - **The low engine utilization factor (operating at well below the rated capacity) resulted in reduced system efficiencies**
 - **Result: Negative cash-flow**
 - **CHP system shut-down in 2004**

Project Outcome and Financials (cont'd)

- In response to the problems incurred by Barham Farms, an analysis of the anaerobic digester / CHP system design was conducted by the CHP Application Program at North Carolina State University
- The study revealed that a properly designed 50kW CHP system would have provided a much better match between the digester and engine configuration
- This sized system would result in approximately \$38,000 per year savings on the farm's electric utility costs, providing a 6 year simple payback on the total investment

Case Study 4: Smithfield Foods/ Vestal Farms

- **10,000 Head Finishing Operation**
- **100,000 gallons/day manure**
- **30 kW Capstone Microturbine**
- **Biogas Produced: 45,000 cf/day**
- **Recovered Heat: 5,800 MMBtu/Year
(estimated)**

Financials

- **Microturbine
heat recovery equipment
engineering: \$120,000**
- **Annual Projected
Savings from recovered
thermal energy: \$ 46,250**
- **Estimated Incremental
Payback on
Microturbine Installation: 2.6 Years**



Project Outcome

- The CHP system at Vestal Farm is very well matched to the thermal needs of the anaerobic digester
- The microturbine's thermal recovery is sufficient to maintain the heat at 95°F in the anaerobic digester for about 7 months of the year and at about 85°F during the winter months; minimal supplemental heat is provided by an additional burner during the winter months
- Facility is installed and tested. Operator is currently negotiating stand-by power contract with incumbent utility

In Summary

- **Combined Anaerobic Digesters/CHP Systems installed have been shown to work across:**
 - **Different anaerobic digester technologies**
 - **Different climates**
 - **Different utility territories (with different buy-back rates and stand-by tariffs)**
 - **Different regulatory structures and manure management requirements**
- **If the AD/CHP System is**
 - **Properly designed**
 - **Installed**
 - **Maintained**

